

ADDENDUM NO. 2

**CITY OF HIALEAH
72 UNIT ELDERLY HOUSING
275 PALM AVE.
HIALEAH, FLORIDA**

DECEMBER 19, 2012

TO ALL CONCERNED

The original Contract Documents, for the Project entitled **CITY OF HIALEAH – 72 Unit Elderly Housing, RAILINGS AND MISCELLANEOUS METALS BID NO. 2012/13-3230-00-023** is hereby amended as noted in this **Addendum No. 2**.

This **Addendum No. 2** consists of 1 Typed Pages, 2 Sketches, 0 Attachments and 0 Drawings. All other items and conditions of the original Contract Documents shall remain unchanged. This Addendum shall become a part of the Contract Documents.

Approved for issue:  Date: December 19, 2012
Luis Azan - Project Manager

ACKNOWLEDGEMENT

Receipt of this **Addendum No. 2** shall be acknowledged in the space provided on the ADDENDUM RECEIPT FORM (ARF) (copy attached) now a part of the Contract Documents faxed immediately to City of Hialeah @ (305) 687-2642, and submitted with sealed bids.


IN THE CONTRACT DOCUMENTS:

Response to RFI from Marrero Group dated December 14, 2012:

Please provide the following details for the 72 Unit project involving Iron Work:

- 1) The size of the perforations on the decorative screens on the balconies.
See Architect's sketch attached, 'Pattern of Perforations on Screens' (Pages 1 & 2)
- 2) Please provide the type of finish on the decorative screens on the balconies.
Decorative Screens: Aluminum Silver powder coat
Railings: White
- 3) Please provide the location and quantity of the bollards (Detail 11, Page AS-002).
There are no indications on the plans that bollards are to be provided. Typically when a 6" high curb or sidewalk is provided, as in this case, bollards are not required. Sidewalk along the perimeter of the building is supposed to be 6" high.
- 4) Are the concrete columns on the perimeter fence being installed by the shell contractor or the Iron contractor?
(Detail 10, Page A-701)
Bidders are not to include the perimeter fence or concrete columns in their proposals.

RAILINGS & MISCELLANEOUS METALS-BID #2012/13-3230-00-023



**PATTERN OF PERFORATIONS ON SCREEN
ON BALCONIES BLOW UP - RFI**

